

Ref. No: 01/2025

Meppayur Primary Health Centre Meppayur P.O

SANITARY CERTIFICATE

As per the Govt. Notification No. 1054/G3/79 HD-II dated 27th June 1979

I, GIREESH KUMAR A.M.....Health Inspector of PHC Meppayur

and Health Officer Of Meppayur Grama Panchayath are do hereby certify that the site in R.S. No:.....

.....Building No. XIV/205.....Of

Meppayur Grama Panchayath Proposed For SIRAJUL HUDA ENGLISH.....

MEDIUM SCHOOL-MEPPAYUR.....owned

by PRINCIPAL.....

has inspected by me and the sanitary arrangements made at present are satisfactory. Hence a Sanitary fitness certificate issued to run the above thing subject to the condition laid down in the order. Any violation of anyone of the conditions in the public health law Will automatically invalid this certificate. I recommend to issue the running licence for the purpose.

This certificate is issued only for the above purpose under the building ownership of.....

Renewal of Application......

Inspected on 12-12-2025.....

Place: Meppayur

Date 16-12-2025



Signature of Health Inspector
HEALTH INSPECTOR
PRIMARY HEALTH CENTRE
MEPPAYUR, KOTHAKKUDY DIST
PIN - 673 524

NB:

2003 ലെ COTPA നിയമപ്രകാരമുള്ള പുകവലി നിരോധന ബോർഡ് സ്ഥാപനത്തിൽ പ്രദർശിപ്പിക്കേണ്ടതാണ്.

True Copy

PRINCIPAL
SIRAJUL HUDA ENGLISH MEDIUM SCHOOL
Meppayur, Manhakkulam

Manager
Sirajul Huda English Medium School
Meppayur, Manhakkulam



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB
KOYILANDY, KOZHIKODE
NABL RECOGNISED DRINKING WATER TESTING LABORATORY
E-mail: waterqualitykoy@gmail.com
Ph: 9744014972

TEST REPORT

Report No - KWA/KKD/KOY/4004/26

Date of Report: 29/07/2026

SIRAJUL HUDA ENGLISH MEDIUM SCHOOL C/O PRINCIPAL KEEZHARIYUR	Customer Name & Address	1.Sample received on	: 28/07/2026
		2.Sample condition	: GOOD
		3.Sampling done by	: HEALTH INSPECTOR
		4.Sample code	: KOY 4004/26
		5.Source of sample	: OPEN WELL
		6.Sample quantity	: 1 LTR
		7.Page No	: 1/1
		8.Test performing dates	From: 28/07/2026 To: 29/07/2026

	Characteristics	Unit	Test Method	Acceptable limits as per IS 15185-2021	Result
1	Coliforms	CFU/100ml	IS 15185(part1) 2002 reaffirmed 2016	Shall not be detectable in any 100ml sample	ABSENT
2	E coli	CFU/100ml	IS 15185(part1) 2002 reaffirmed 2016	Shall not be detectable in any 100ml sample	ABSENT

TNTC: TOO NUMEROUSE TO COUNT (COUNT MORE THAN 300CFU/100ML)

Remarks: - The results reported relate only to the sample received and tested. This test Report shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed By:

MR

Authorized By:

[Signature]

[Signature]
PRINCIPAL
SIRAJUL HUDA ENGLISH MEDIUM SCHOOL
Meppayur, Manhakkulam

End of Report

[Signature]
Manager
Sirajul Huda English Medium School
Meppayur, Manhakkulam



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB
KOYILANDY, KOZHIKODE
NABL RECOGNISED DRINKING WATER TESTING LABORATORY
E-mail: waterqualitykoy@gmail.com
Ph: 9744014972

TEST REPORT

Report No - KWA/KKD/KOY/3517/26

Date of Report: 30/06/2026

CUSTOMER NAME & ADDRESS SIRAJUL HUDA ENGLISH MEDIUM SCHOOL C/O PRINCIPAL MANHAKKULAM MEPPAYUR	1. Sample received on	: 27/06/2026
	2. Sample condition	: GOOD
	3. Sampling done by	: HEALTH INSPECTOR
	4. Sample code	: KOY 3517/26
	5. Source of sample	: OPEN WELL
	6. Sample quantity	: 1 LTR
	7. Page No	: 1/1
	8. Test performing dates	From: 27/06/2026 To: 30/06/2026

Sl. No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
01	Colour	HU	IS 3025 (part 4)-2021 (PLATINUM COBALT VISUAL COMPARISON METHOD)	5	<5.0
02	Odour		IS 3025 (part 5)-2018	Agreeable	Agreeable
03	Turbidity	NTU	IS 3025 (part 10)-1984 (NEPHLOMETRIC METHOD)	1	1.51
04	pH at 25 °C		IS 3025 (PART 11)-2022	6.5 to 8.5	6.28
05	Alkalinity	Mg/L	IS 3025 (PART 23)-1986 (INDICATOR METHOD)	200	ND
06	Total Dissolved Solids at 180°C	mg/L	IS 3025 (part 16)-2023 (GRAVIMETRIC METHOD)	500	69.02
07	Total Hardness (as CaCO ₃)	mg/L	IS 3025 (part 21)-2009 (EDTA METHOD)	200	41.58
08	Calcium (as Ca)	mg/L	IS 3025 (part 40)-1991 (EDTA METHOD)	75	ND
09	Magnesium (as Mg)	mg/L	IS 3025 (part 46)-1994 (TITRATION METHOD)	30	ND
10	Chloride (as Cl)	mg/L	IS 3025 (part 32)-1988 (ARGENTENOMETRIC METHOD)	250	9.97

NB: - 1) The results reported relate only to the samples received and tested. This test Report shall not be reproduced except in full without the written approval of the Laboratory.

2) Retention days of sample is 15 days.

Reviewed By:

[Signature]



End of Report

Authorized By: *[Signature]*
(Name & Signature)

DEPUTY QUALITY MANAGER
KERALA WATER AUTHORITY
SUB DISTRICT LABORATORY
KOYILANDY, KOZHIKODE

Manager

Sirajul Huda English Medium School
Meppayur, Manhakkulam

Issue No. 01

Issue Date: 03/01/22

Rev. No. 01

True copy
[Signature]
KWA/KKD/KOY/F4
PRINCIPAL
SIRAJUL HUDA ENGLISH MEDIUM SCHOOL
Meppayur, Manhakkulam



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB
KOYILANDY, KOZHIKODE
NABL RECOGNISED DRINKING WATER TESTING LABORATORY
E-mail: waterqualitykoy@gmail.com
Ph: 9744014972

TEST REPORT

Report No - KWA/KKD/KOY/3517/26

Date of Report: 30/06/2026

Customer Name & Address	1. Sample received on	: 27/06/2026
SIRAJUL HUDA ENGLISH MEDIUM SCHOOL C/O PRINCIPAL MANHAKKULAM MEPPAYUR	2. Sample condition	: GOOD
	3. Sampling done by	: HEALTH INSPECTOR
	4. Sample code	: KOY 3517/26
	5. Source of sample	: OPEN WELL
	6. Sample quantity	: 1 LTR
	7. Page No	: 1/1
	8. Test performing dates	From: 27/06/2026 To: 30/06/2026

Sl. No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Electrical conductivity at 25°C	Micro mhos/cm	IS 3025 (part 14)-2013 (Reaffirmed 2019)		101.5
2	Acidity	mg/L	IS 3025 (part 22)-1986 (Reaffirmed 2019)		ND
3	Sulphate (as SO ₄)	mg/L	IS 3025 (PART 24)-1986 (Reaffirmed 2019)	200	ND
4	Phosphate [as PO ₄]	mg/L	IS 3025 (PART 31)-2008 (Reaffirmed 2019)		BDL
5	Iron (as Fe)	mg/L	IS 3025 (part 53)-2003 (Reaffirmed 2014)	1.0	0.06
6	Nitrate (as NO ₃)	mg/L	APHA4500NO ₃ -B 23rd Edition	45	5.20
7	Ammonia	mg/L	IS 3025 (part 34)-2008 (Reaffirmed 2019)	0.5	BDL
8	Residual Chlorine	mg/L	IS 3025 (part 26)-1986 (Reaffirmed 2019)	0.2	BDL

BDL → Below Detection Level

ND → NOT DONE

NB-The results reported relate only to the samples received and tested. This test Report shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed By:

Authorized By:



End of Report

KWA/QC/KKD/KOY/F4

Issue No. 01

Issue Date: 03/01/22

Rev. No. 01

Rev. Date: 20/05/23

PRINCIPAL
SIRAJUL HUDA ENGLISH MEDIUM SCHOOL
Meppayur, Manhakkulam

Manager
Sirajul Huda English Medium School
Meppayur, Manhakkulam



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB
KOYILANDY, KOZHIKODE
NABL RECOGNISED DRINKING WATER TESTING LABORATORY
E-mail: waterqualitykoy@gmail.com
Ph: 9744014972

TEST REPORT

Report No - KWA/KKD/KOY/3517/26

Date of Report: 30/06/2026

SIRAJUL HUDA ENGLISH MEDIUM SCHOOL C/O PRINCIPAL MANHAKKULAM MEPPAYUR	1. Sample received on	: 27/06/2026
	2. Sample condition	: GOOD
	3. Sampling done by	: HEALTH INSPECTOR
	4. Sample code	: KOY 3517/26
	5. Source of sample	: OPEN WELL
	6. Sample quantity	: 100 ML
	7. Page No	: 2/2
	8. Test performing dates	From: 27/06/2026 To: 30/06/2026

	Characteristics	Unit	Test Method	Acceptable limits as per IS 15185-2021	Result
1	Coliforms	CFU/100ml	IS 15185(part1) 2002 reaffirmed 2016	Shall not be detectable in any 100ml sample	PRESENT TNTC
2	E coli	CFU/100ml	IS 15185(part1) 2002 reaffirmed 2016	Shall not be detectable in any 100ml sample	ABSENT

TNTC: TOO NUMEROUSE TO COUNT (COUNT MORE THAN 300CFU/100ML)

Remarks: - The results reported relate only to the sample received and tested. This test Report shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed By:

[Signature]



End of Report

Authorized By:

QUALITY MANAGER
KERALA WATER AUTHORITY
SUB DISTRICT LABORATORY
KOYILANDY, KOZHIKODE

KWA/KKD/KOY/F4

Issue No. 01

Issue Date: 03/01/22

Rev. No. 01

Rev. Date: 20/05/23

PRINCIPAL
SIRAJUL HUDA ENGLISH MEDIUM SCHOOL
Meppayur, Manhakkulam

Manager
Sirajul Huda English Medium School
Meppayur, Manhakkulam